



vR production (DUKTUS) gmbh
Sophienstraße 52-54
35576 Wetzlar
Deutschland

Magistratsabteilung 39
Rinnböckstraße 15/2
1110 Wien
Telefon +43 1 4000 8039
Fax +43 1 4000 99 8039
post@ma39.wien.gv.at
ma39.wien.at

MA 39 – 21-00641-006

Wien, 12. April 2021

Attestation of Inspection 2021

Applicant and production plant:	vR production (DUKTUS) gmbh D-35576 Wetzlar
Object of inspection	Ductile iron pipes and fittings for sewerage applications, type variation: TYTON, TYTON-TIS-K, TYTON-SIT, TYTON-NOVO-SIT, VRS, BLS, BRS and flange, nominal size DN 80 to DN 1000
Date of inspection	April 9, 2021
Inspection program	third party inspection according to ISO 7186, DIN EN 598 and FGR 61 based on the inspection contract MA 39 – ROR – Ü 1557/2018: <ul style="list-style-type: none">• Inspection of the production process• Inspection of the factory production control• Testing of products
Result of the inspection	The factory production control as well as the test results comply with the requirements according to ISO 7186, DIN EN 598 and FGR 61

Official
Ing. Bernhard Wihlidal

Head of the laboratory
Dipl.-Ing. Andreas Tichy
Oberstadtbaurat

Head of testing, inspection and
certification body
Dipl.-Ing. Georg Pommer
Senatsrat

The inspection plus the performed tests and their results are documented in the inspection report MA 39 - VFA 21-00641-002.
In any case of doubt the attestation MA 39 – VFA 21-00641-004 in German language is binding.